



GOVERNMENT OF TAMILNADU
DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

R.No: 0245/2025/PHC Dated: 23/09/2025/DHO-KPM Office of the,
District Health Officer,
Kancheepuram,

Date: 25.09.2025

HEALTH CLEARANCE (SANITARY) CERTIFICATE

(Under The Tamil Nadu Public Health Act -1939)
(Under Tamilnadu Educational Rules - Appendix - 3 - Chapter III - Rule -24)
(VALID UPTO 24.09.2026)

(Issued to **M/s. SRI KRISHNA VIDHYA MANDHIR**, Located at Panapakkam, Near Padappai, Via.Tambaram, Chennai - 601 301, Kundrathur Taluk, Kancheepuram District)

I hereby declare that I have inspected **M/s. SRI KRISHNA VIDHYA MANDHIR**, Located at Panapakkam, Near Padappai, Via.Tambaram, Chennai - 601 301, Kundrathur Taluk, Kancheepuram District on 22.09.2025 and certify.

- That the Building is properly white washed / painted neat and clean.
- That the supply of drinking water is wholesome.
- That the liquid and solid wastages are disposed of in sanitary manner.
- That the sewage disposal pit (septic tank) etc, is maintained as per rules.
- That in all necessary aspects, the sanitation is good.

The Sanitary Certificate is issued Subject to the following conditions:

- All staff and students must be screened by infrared thermal scanner before entering into the premises.
- All the surfaces of the School premises should be thoroughly disinfected three times in a day.
- All the staffs and students should compulsory wear face mask, hand gloves and to maintain social distance about 6 feet.
- If anyone suffering from fever, cold, cough and difficulty in breathing, it should be informed to the local health authority.
- The establishment should ban Cigarette and other tobacco products in the campus and visible 'No Smoking' board should be displayed as per COTPA ACT 2003.
- Unnecessary containers or things should be disposed to frequently to avoid **mosquito breeding** for the prevention and control of vector borne diseases.
- The number of urinals / toilets should be increased according to staff's and student's strength.
- Child labour should not be engaged.
- Occurrence of any contagious disease should be informed to the Undersigned to take necessary action.

Counter Signed

Dr. 25/9/25

District Health Officer
Kancheepuram.

**District Health Officer
Kancheepuram District**

Jh. a. Dm. 25/9/25
BLOCK HEALTH SUPERVISOR
GOVERNMENT PRIMARY HEALTH CENTRE,
Elichur, KUNDRATHUR BLOCK,
KANCHEEPURAM DISTRICT

Telephone: 044-2999 7572.



DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

From

Tmt.L.Sujatha, M.Sc., M.A., B.Ed.,
CHIEF WATER ANALYST,
Chief Water Analysis Laboratory,
King Institute Campus, Guindy,
Chennai-600 032.

To

The Principal,
Sri Krishna Vidhya Mandhir,
Panapakkam Village (near) Padappai,
Kundrathur Taluk,
Kancheepuram District – 601 301.

R.No.1023 /C/2026 Misc –246 & 247

Dated : 30.04.2026.

Sir/Madam,

Sub : Report on examination of water samples - Regarding.
Ref : Your letter dated 02.04.2026.

Two samples of water stated to have been collected on 09.04.2026 by the School Staff from the following source/point located within the premises of Sri Krishna Vidhya Mandhir, Panapakkam Village, near Padappai, Kundrathur Taluk, Kancheepuram District were received at this laboratory on the same day from the addressee to assess their suitability for drinking purposes.

1. Water from the Bore well (MISC 246)
2. Water from the RO Plant outlet tap at 1st Floor of the Hostel (MISC 247)

The Results of analysis are furnished over leaf.

1. Water from the Bore well (MISC 246)

The above sample of water is Colourless and clear in physical appearance.

Chemical analysis reveals that it is moderately hard and highly alkaline in nature. It is considered to be acceptable chemical quality for drinking purposes.

However, it is of poor bacteriological quality for drinking purposes as evidenced by the presence of Coliform group of Organisms.

It also reveals the presence of few microscopical organisms.

Hence the source of water needs disinfection before consumption.

RESULTS OF EXAMINATION OF SAMPLES OF WATER

From : The Principal, Sri Krishna Vidhya Mandhir, Panapakkam Village (near) Padappai,
Kundrathur Taluk, Kancheepuram District.

Collected by : School Staff.

M - 246

M - 247

Date of Collection : 09.04.2026		Water from the Bore well	Water from the RO Plant outlet tap at 1 st Floor of the Hostel	Maximum permissible limit for drinking water as per BIS 10500/2012
Date of Receipt : 09.04.2026				
Source as per label:				
Bacteriological Examination	Total colonies per ml on agar at 37°C	150	50	10
	MPN of Coliform bacteria per 100 ml.	210	210	0
	Nature of Coliform bacteria isolated	Citrobacter Ferundii - I	Irregular VI	absent
	Result of Vibrio test.			
Physical Examination	Colour	Colourless	Colourless	Colourless
	Turbidity (Units)	5	3	5
	Smell	None	None	None
Chemical Examination (in mg/l).	Total dissolved Solids	690	80	2000
	Carbonate hardness as CaCO ₃	192	10	-
	Non- Carbonate hardness as CaCO ₃	0	0	-
	Total hardness as CaCO ₃	192	10	600
	Chloride as Chlorine	78	19	1000
	Ammoniacal nitrogen	-	-	Nil
	Albuminoid nitrogen	-	-	Nil
	Oxygen absorbed (Tidy's test)	0.88	0.88	-
	Nitrate-nitrogen	1.0	0.5	10.2
	Alkalinity } as CaCO ₃ } Phenolphthalein Methyl Orange	0	0	-
		420	40	600
	Fluoride as Fluorine	0.2	0.1	1.5
	PH.	6.8	6.5	6.5-8.5
	Iron as Fe Total	0.05	0.05	1.0
	Ferrous	Nil	Nil	--
	Manganese as Mn.	Nil	Nil	0.3
	Qualitative-			
	Nitrite nitrogen	Trace	Trace	Trace
	Sulphate	Trace	Trace	400
	Phosphate	Trace	Trace	Trace
Toxic substances				
Electrical conductivity (Reciprocal megohms per Cm ³ at 20°C)	980	120	-	
Microscopical Examination	Monas & Amorphous Matter	Monas & Amorphous Matter		

Method of Disinfection :

The disinfection is usually carried out by chlorinating the water collected from the Source (Bore well) at the storage units (OHT/ Sump) by using 4 gms of BIS grade bleaching powder containing 32 to 34 % of chlorine content or 20 ml of 4 to 6 % sodium hypochlorite solution for every 1000 litres of water with half an hour contact time before Consumption.

The Storage units should be cleaned with strong Bleaching powder solution periodically atleast twice in a month to ensure hygienic safety of storage units and to prevent the growth of Spores and Thermophilic bacteria.

2. Water from the RO Plant outlet tap at 1st Floor of the Hostel (MISC 247)

The above sample of RO water is colourless and clear in physical appearance.

Chemical analysis reveals that it is very soft and less mineralized and it is of usable chemical quality for drinking purposes.

It is of poor bacteriological quality for drinking purposes as evidenced by the presence of Coliform group of Organisms.

It also reveals the presence of few microscopical organisms.

Hence it is advised to set right the RO unit by contacting the supplier of the RO unit with this analytical report so that the RO outlet water should be free from bacteria and to get hygienically safe potable water at all times.

Further, the RO Tank should be cleaned periodically and the RO filters should be changed periodically based on the supplier's manual.

Copy to: Lab & File

P. Yoganathan
4.5.2026
for CHIEF WATER ANALYST,
Chief Water Analysis Laboratory,
Guindy, Chennai - 32.

for
04/05/2026

ANNEXURE C

Appendix XIII

**DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE
SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

L.Dis.No. 2557 /A3/2026

Dated : 13.05.2026

It is certified that an inspection team headed by **M.VENKATESAN BLOCK HEALTH SUPERVISOR** from **ELIZHUR GPHC, KUNDRATHUR BLOCK** from Public Health and Preventive Medicine Department inspected the **M/s.SRI KRISHNA VIDHYA MANDHIR (CBSE), Panapakkam Village, Near Padapai, (Via) Tambaram, Kundrathur Taluk, Kanchipuram District - 601301** on **12.05.2026** checked the water test report submitted by the School and found the **SRI KRISHNA VIDHYA MANDHIR (CBSE)**, has portable drinking water facilities for the students and members of staff of the institution and maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State / U.T Government.

The above Certificate is valid for a Period of **ONE YEAR**



Block Health Supervisor
Govt.Primary Health Center
Ezhichur, Kundrathur Block,
Kancheepuram District.

Name : **Dr.T.R.Senthil, MBBS, DPH, DIH,**
Designation : District Health officer
Name & address of the office : District Health Office, Kancheepuram
: Kancheepuram District.
**DISTRICT HEALTH OFFICER
KANCHEEPURAM DISTRICT.**

Dr. T.R. Senthil
13/5/26

To
**SRI KRISHNA VIDHYA MANDHIR (CBSE),
Panapakkam Vilalge,
Kundrathur Taluk,
Kancheepuram District - 601301**